



Plantweb Optics Data Lake

System Connectivity List

This table contains a list of all 125+ systems that Plantweb Optics Data Lake is able to connect to. These systems have all been successfully connected to, in either production or test environments. This list will be updated when connectivity to new systems is established or new information about existing system connectivity is discovered.

| Vendor | System | System Type | Protocol | Version | Notes / Limitations |
|--------|---|---------------------|----------|-------------|---------------------------------|
| ABB | 800xA | DCS | OPC A&E | | ABB.HsOPCAEserver.1 |
| ABB | 800xA | DCS | OPC DA | | ABB.Shadow.OPCServer |
| ABB | 800xA Asset Optimization | Asset Monitoring | OPC DA | 5.1100.5947 | ABB.AfwOpcDaSurrogate.1 |
| ABB | 800xA Asset Optimization | Asset Monitoring | OPC DA | 5.1100.6386 | ABB.AfwOpcDaSurrogate.1 |
| ABB | 800xA Asset Optimization | Asset Monitoring | OPC DA | 5.300.4206 | ABB.AfwOpcDaServer.1 |
| ABB | 800xA Asset Optimization | Asset Monitoring | OPC DA | 5.300.4206 | ABB.AfwOpcDaSurrogate.1 |
| ABB | 800xA Core Alarm & Event Server | | OPC A&E | 5.0.0 | ABB.OPCEventServer.1 |
| ABB | 800xA for Advant Master | DCS | OPC A&E | 5.300.10520 | ABB.AdvMbAe.OPCEventServer.1 |
| ABB | 800xA History Server (in-proc server) | Process Historian | OPC HDA | 1.1.1 | ABB.AdvHtHistoryHdlr.1 |
| ABB | 800xA History Server (out-of-proc server) | Process Historian | OPC HDA | 1.1.1 | ABB.AdvHtHistorySrv.1 |
| ABB | 800xA Soft Alarm Server | DCS | OPC A&E | 5.0.0 | ABB.AdvAeSoftAlarmOPCServer.1 |
| ABB | 800xA System Message Server | DCS | OPC A&E | 5.0.0 | ABB.SystemMessageOPCServer.1 |
| ABB | ABB FOUNDATION Fieldbus | FOUNDATION Fieldbus | OPC DA | | ABB.Fieldbus.OPCServer.DA |
| ABB | 800xA | DCS | OPC A&E | 1.60.8819 | ABB.AdsAeHdlr.1 |
| ABB | Freelance | DCS | OPC DA | | Freelance2000OPCServer.1 |
| ABB | IM Archive AE Server | Process Historian | OPC A&E | 1.1.1 | ArchiveService.OPCEventServer.1 |

Plantweb Optics Data Lake

System Connectivity List

| | | | | | |
|------------------------|--|---------------------|-------------------|-----------|-------------------------|
| Aspen Technology, Inc. | Aspen Production Record Manager (APRM) | Batch Record System | AspenTech SQLplus | | Formerly Batch.21 |
| Aspen Technology, Inc. | InfoPlus.21 | Process Historian | OPC DA | 11.2.801 | Aspen.Infoplus21_DA.1 |
| Aspen Technology, Inc. | InfoPlus.21 | Process Historian | OPC DA | 12.7.316 | Aspen.Infoplus21_DA.1 |
| Aspen Technology, Inc. | InfoPlus.21 | Process Historian | OPC DA | 12.8.5513 | Aspen.Infoplus21_DA.1 |
| Aspen Technology, Inc. | InfoPlus.21 | Process Historian | OPC DA | 12.8.5611 | Aspen.Infoplus21_DA.1 |
| Aspen Technology, Inc. | InfoPlus.21 | Process Historian | OPC DA | 14.1.213 | Aspen.Infoplus21_DA.1 |
| Aspen Technology, Inc. | InfoPlus.21 | Process Historian | OPC DA | 15.0.126 | Aspen.Infoplus21_DA.1 |
| Aspen Technology, Inc. | InfoPlus.21 | Process Historian | OPC DA | 15.1.135 | Aspen.Infoplus21_DA.1 |
| Aspen Technology, Inc. | InfoPlus.21 | Process Historian | OPC DA | 15.1.48 | Aspen.Infoplus21_DA.1 |
| Aspen Technology, Inc. | InfoPlus.21 | Process Historian | OPC DA | 16.0.256 | Aspen.Infoplus21_DA.1 |
| Aspen Technology, Inc. | InfoPlus.21 | Process Historian | OPC DA | 16.0.404 | Aspen.Infoplus21_DA.1 |
| Bently Nevada | System 1 | Asset Monitoring | OPC DA | | Bently.Sys1OPCServer.1 |
| Bruel & Kjaer | | Asset Monitoring | OPC UA | | |
| CoDeSys | Control Runtime Toolkit | Automation Platform | OPC A&E | | |
| CoDeSys | Control Runtime Toolkit | Automation Platform | OPC DA | | CoDeSys.OPC.DA |
| Crestron | CP3 | Control System | TCP/IP | | |
| Emerson Electric Co. | DeltaV | DCS | OPC A&E | 11.3.4331 | DeltaV.OPCEventServer.1 |
| Emerson Electric Co. | DeltaV | DCS | OPC A&E | 13.3.5823 | DeltaV.OPCEventServer.1 |

Plantweb Optics Data Lake

System Connectivity List

| | | | | | |
|-------------------------|-------------------------------------|-------------------|--------------------|-----------|---------------------------------------|
| Emerson Electric Co. | DeltaV | DCS | OPC A&E | 13.3.6300 | DeltaV.OPCEventServer.1 |
| Emerson Electric Co. | DeltaV | DCS | OPC A&E | 13.3.6317 | DeltaV.OPCEventServer.1 |
| Emerson Electric Co. | DeltaV | DCS | OPC A&E | 13.3.6330 | DeltaV.OPCEventServer.1 |
| Emerson Electric Co. | DeltaV | DCS | OPC DA | | DeltaV.DVSYSSvr.1 |
| Emerson Electric Co. | DeltaV | DCS | OPC HDA | | DeltaV.OPCHDAsvr.1 |
| Emerson Electric Co. | DeltaV | DCS | OPC DA | | DELTAV.SisOpcSvr.1 |
| Emerson Electric Co. | DeltaV | DCS | OPC DA | | OPC.DeltaV.1 |
| GE Bently Nevada | System 1 | Asset Monitoring | OPC DA | 1.0.0 | Bently.Sys1EnterpriseOPCServer.1.1_DA |
| GE Bently Nevada | System 1 | Asset Monitoring | OPC DA | 9.0.0 | GE.BentlyNevada.Sys1OPCServer.1 |
| GE Fanuc | Proficy iFIX | HMI | OPC DA | 1.1.1 | Intellution.OPCiFIX.1 |
| GE Fanuc | Proficy iFIX | HMI | OPC DA | | Intellution.iFixOPCClient |
| GE Fanuc | Proficy iFIX | HMI | OPC DA | | Intellution.OPCEDA.3 |
| HIMA | Smart Safety Platform | Safety System | OPC A&E | | HIMA.AlarmEventServer |
| HIMA | Smart Safety Platform | Safety System | OPC DA | | HIMA.ModbusOPCServer |
| Honeywell International | Experion PKS | DCS | OPC DA + A&E | | Hci.TPNServer |
| Honeywell International | Experion PKS | DCS | OPC DA + A&E + HDA | | Honeywell |
| Honeywell International | Experion PKS | DCS | OPC DA | | Hci.spssdss |
| Honeywell International | Experion PKS | DCS | OPC DA + A&E | | HWHsc.OPCServer |
| Honeywell International | Experion PKS | DCS | OPC A&E | | Hci.SysEvtSvr |
| Honeywell International | MatrikonOPC Desktop Historian (ODH) | Process Historian | OPC DA + A&E + HDA | | Matrikon.OPC/DesktopHistorian.1 |
| Honeywell International | MatrikonOPC Funnel | OPC Connectivity | OPC DA + A&E + HDA | | Matrikon.OPC.OPCFunnel.1 |
| Honeywell International | MatrikonOPC Redundancy Broker (ORB) | OPC Connectivity | OPC DA + A&E + HDA | | ORB |

Plantweb Optics Data Lake

System Connectivity List

| | | | | | |
|-------------------------|------------------------------|-------------------|--------------------|-------------|--|
| Honeywell International | MatrikonOPC Server for IP.21 | OPC Connectivity | OPC DA + A&E + HDA | | Matrikon.OPC.IP21.1 |
| Honeywell International | MatrikonOPC Simulation | OPC Connectivity | OPC DA + A&E + HDA | 1.5.0 | Matrikon.OPC.Simulation.1 |
| Honeywell International | MatrikonOPC Sniffer | OPC Connectivity | OPC DA + HDA | | Matrikon.OPC.Sniffer.1 |
| Honeywell International | Operational Insight | OPC Connectivity | OPC DA | | Matrikon.OPC.NetCalc |
| Honeywell International | Proficy iFIX | HMI | OPC A&E | | Proficy.OPCiFIXAE.1 |
| Honeywell International | Unifformance PHD | Process Historian | OPC DA | 321.1.0 | OPC.PHDServerDA.1 |
| Honeywell International | Unifformance PHD | Process Historian | OPC HDA | 321.1.0 | OPC.PHDServerHDA.1 |
| Honeywell International | Unifformance PHD | Process Historian | PHD .NET wrapper | | |
| IBM | Watson | Cloud | MQTT | | as Publisher |
| ifm electronic | efector octavis | Asset Monitoring | OPC A&E | | ifm.OPC.OPCServer.AE.1 |
| Microsoft Corporation | Azure Event Hub | Cloud | Kafka | | as Event Producer / Event Publisher |
| Microsoft Corporation | Azure IoT Hub | Cloud | MQTT | | as Publisher |
| Microsoft Corporation | SQL Server | RDBMS | ODBC | 2019 / 15.0 | |
| Microsoft Corporation | Time Series Insight | Cloud | MQTT | | IoT Hub |
| Microsoft Corporation | Time Series Insight | Cloud | Kafka | | Event Hub |
| MongoDB Inc. | MongoDB | Document Database | mongodb driver | | |
| MongoDB Inc. | MongoDB | Document Database | mongodb driver | | |
| National Instruments | LabVIEW | HMI | OPC DA | | National Instruments.Variable Engine.1 |
| Omron | Omron PLC | PLC | OPC UA | | via. Kepware OPC |
| OPC Foundation | OPC Classic Client Analyzer | OPC Connectivity | OPC DA | | OpcTestLab.OpcAnalyzer.1 |
| Oracle Corporation | Oracle Database | RDBMS | ODBC | 12c | |
| OSIsoft | PI System | Process Historian | OPC DA + HDA | 1.2.7 | OSI.DA.1 |
| OSIsoft | PI System | Process Historian | OPC DA + HDA | 1.2.7 | OSI.HDA.1 |

Plantweb Optics Data Lake

System Connectivity List

| | | | | | |
|-------------------------|--------------------------|---------------------|-----------------------|--------------|--------------------------------------|
| OSISoft | PI System | Process Historian | OPC DA | 2.0.0 | OSISoft.OPCDA2.DA.1 |
| OSISoft | PI System | Process Historian | OPC DA | 2.2.0 | OSISoft.OPCDA2.DA.1 |
| OSISoft | PI System | Process Historian | OPC DA + HDA | 2.3.0 | OSI.DA.1 |
| OSISoft | PI System | Batch Record System | PI AF / PI SDK | | via. inmation PIBridge |
| OSISoft | PI System | Process Historian | PI AF / PI SDK | | |
| ProSCADA | OPC Server for PCS 7 | OPC Connectivity | OPC DA | | ProScada.SiemensIE.7.9.52.0 |
| Raspberry Pi Foundation | Raspberry Pi | IoT | OPC UA | | via. Codesys Control Runtime Toolkit |
| Rockwell Automation | Allen-Bradley Logix 5000 | PLC | EtherNet/IP | | |
| SAP | S/4HANA | ERP | HTTP | | IDOC over HTTP bidirectional |
| Schneider Electric | ClearScada | SCADA | OPC DA | | |
| Schneider Electric | Wonderware Historian | Process Historian | OPC DA | | AVEVA |
| Schneider Electric | Wonderware Historian | Process Historian | ODBC | | AVEVA |
| Semtech | LoRaWAN | IoT Network | MQTT | | |
| Siemens | SIMATIC NET | OPC Connectivity | OPC DA | | OPC.SimaticNET |
| Siemens | SIMATIC NET | OPC Connectivity | OPC DA | | OPC.SimaticNET.DP.1 |
| Siemens | SIMATIC NET | OPC Connectivity | OPC DA | | OPC.SimaticNET.PD |
| Siemens | SIMATIC PCS 7 | DCS | OPC A&E | 3.9.10101 | PCS7.OPCAEServer.1 |
| Siemens | SIMATIC PCS 7 | DCS | OPC DA | 3.9.10101 | PCS7.OPCDAServer.1 |
| Siemens | SIMATIC PCS 7 | DCS | OPC DA | 3.9.10101 | PCS7.OPCDAServer.1 |
| Siemens | SIMATIC PCS 7 | DCS | OPC A&E | 3.9.10201 | PCS7.OPCAEServer.1 |
| Siemens | SIMATIC PCS 7 | DCS | OPC DA | 3.9.10201 | PCS7.OPCDAServer.1 |
| Siemens | SIMATIC PCS 7 | DCS | OPC A&E | 3.9.10202 | PCS7.OPCAEServer.1 |
| Siemens | SIMATIC PCS 7 | DCS | OPC A&E | 3.9.11101 | PCS7.OPCAEServer.1 |
| Siemens | SIMATIC PCS 7 | DCS | OPC A&E | 3.9.11301 | PCS7.OPCAEServer.1 |
| Siemens | SIMATIC PCS 7 | DCS | OPC HDA | | PCS7.OPCHDAServer.1 |
| Siemens | SIMATIC S7 | PLC | Siemens S7-TCP/IP TIA | S7 | |
| Siemens | SIMATIC S7 | PLC | Siemens S7-TCP/IP | S7-1200/1500 | |

Plantweb Optics Data Lake

System Connectivity List

| | | | | | |
|----------------------|-------------------------|------------------|-------------------|------------|------------------------------------|
| Siemens | SIMATIC S7 | PLC | Siemens S7-TCP/IP | S7-300/400 | |
| Siemens | SIMATIC WinCC | SCADA + HMI | OPC DA | | OPCServer.WinCC.1 |
| Siemens | SIMATIC WinCC | SCADA + HMI | OPC HDA | | OPCServerHDA.WinCC.1 |
| Siemens | SINUMERIK 840D sl | CNC Machine | OPC UA | | |
| Softing | dataFEED | OPC Connectivity | OPC A&E | | Softing.OPC.DF.Configuration1.AE.1 |
| Softing | dataFEED | OPC Connectivity | OPC DA | | Softing.OPC.DF.Configuration1.DA.1 |
| Softing | OPC Development Toolkit | OPC Connectivity | OPC A&E | | Softing.OPCToolboxDemo_ServerAE.1 |
| Softing | OPC Development Toolkit | OPC Connectivity | OPC DA | | Softing.OPCToolboxDemo_ServerDA.1 |
| Thorsis Technologies | Pro DP/PA Link DTM | OPC Connectivity | OPC DA | 0.1.0 | FDTtoOPC.DA_Server |
| Unified Automation | UaExpert | OPC Connectivity | OPC DA | | OPC.Expert.Classic.Server |
| Wago | WAGO I/O System 750 | PLC | OPC UA | | IoT Edge Gateway |
| Werum IT Solutions | PAS-X | MES | MSI | 1.3 | via DCS BF |
| Werum IT Solutions | PAS-X | MES | MSI | 2 | via DCS BF |
| Werum IT Solutions | PAS-X | MES | MSI | 3.1 | experimental |